

Specific Test List: Draperies, Decorative Materials and Window Treatments

Test	Sample Size	Performance Time
U.S.A. TESTS:		
NFPA 701 (2004 or later):		
Test Method 1	1 yard x full width	5 days
Test Method 2	3 yards x full width	5 - 7 days
Boston Fire Dept.: BFD IX-1	12" x 36"	5 days
California: Fire Marshal Title 19 Small Scale 1237.1	36" x 36"	5 days
Massachusetts (see NFPA 701)		
New York City (see NFPA 701)		
INTERNATIONAL TESTS:		
British Standard: BS 5438	1 yard	7 - 10 days
Canadian Standard: CAN/ULC S109		
Small Scale	1 yard	5 days
Large Scale	3 yards x full width	5 - 7 days
German Standard: DIN 4102, Class B2	1 yard x full width	7 - 10 days

Notes:

1. For these types of products used in the U.S.A., the main test standard is NFPA 701. The other standards listed have specific application depending on the locale. For example, the California Fire Marshal prefers the Title 19 Test. To sum things up, it is strongly suggested that all of these materials be tested to NFPA 701 Test Method 1. If the material is going to a particular locale that has a different test, it is suggested that the second test be conducted also.
2. If the product requires further testing after refurbishing, weathering, etc, please contact Govmark for full details.

The tests contained in this list are not to be considered all-inclusive. Other tests not listed might apply. In order to assure that you are considering the proper test, please contact us or complete a "Request for Quote" form.

The Govmark Organization, Inc.

96 Allen Boulevard, Suite D • Farmingdale, New York 11735-5626 • United States of America
 Tel: +1 631 293-8944 • Fax: + 1 631 293-8956 • www.govmark.com • Email: info@govmark.com

© The Govmark Organization, Inc. - All Rights Reserved.